



Ref. Certif. No.

HU-003282

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Surge Protective Device
Name and address of the applicant	Zhuhai Telehof Electrics Company Limited No.6 Jinhua Road, Xiaolin, Hongqi Town, Jinwan District, Zhuhai, Guangdong, P.R. China
Name and address of the manufacturer	Zhuhai Telehof Electrics Company Limited No.6 Jinhua Road, Xiaolin, Hongqi Town, Jinwan District, Zhuhai, Guangdong, P.R. China
Name and address of the factory	Zhuhai Telehof Electrics Company Limited No.6 Jinhua Road, Xiaolin, Hongqi Town, Jinwan District, Zhuhai, Guangdong, P.R. China
Ratings and principal characteristics	UC:320 V AC (L-N);255 V AC (N-PE);In:30 kA(L-N);50 kA(N-PE) Imax:60 kA(L-N);100 kA(N-PE);Iimp:12.5 kA(L-N);37.5 kA(N-PE) Up:1.8 kV(L-N);1.5 kV(N-PE);Ures:1.35 kV@Iimp;IP code: IP20 ITotal:100 kA(8/20);Modes of protection: L-N, N-PE
Trademark (if any)	Telebahn (logo)
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	BT P BCM12.5 275 RM; BT P BCM25 255 RM; BT P BCM12.5 275 RM/XP; BT P BCM12.5 275 RM/Y+N X=2,3,4; Y=1,2,3
Additional information (if necessary may also be reported on page 2)	Detailed information refer to test report NN20LR1E 001
A sample of the product was tested and found to be in conformity with	IEC 61643-11:2011
As shown in the Test Report Ref. No. which forms part of this Certificate	NN20LR1E 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web:www.tuv.com

Date: 2021-01-23

Signature:

Wencai Zhang