

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	Surge Protective Device
Name and address of the applicant	Zhuhai Telehof Electrics Company Limited No.6 Jinhua Road, Xiaolin, Hongqi Town, Jinwan District, 519090 Zhuhai City, Guangdong Province, China
Name and address of the manufacturer	Zhuhai Telehof Electrics Company Limited No.6 Jinhua Road, Xiaolin, Hongqi Town, Jinwan District, 519090 Zhuhai City, Guangdong Province, China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Zhuhai Telehof Electrics Company Limited No.6 Jinhua Road, Xiaolin, Hongqi Town, Jinwan District, 519090 Zhuhai City, Guangdong Province, China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Test class II / Type 2, (See page 6 of test report 6023130.50 to 6023130.53 for details)
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	BT PCM xyz (RM), BT PCM TN xyz (RM), BT PCM TT 1+1 xyz (RM); BT PCM TT 3+1 xyz (RM), BT PCM TNC xyz (RM), BT PCM TNS xyz (RM); NOTE 1 xyz could be 150, 275, 320 or 385 which corresponds to the voltage rating NOTE 2 RM represents the remote signalling function offered
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61643-11:2011 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6023130.50 to 6023130.53

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2018-07-19

Signature: Kreny Lin

 page 1 of 1