

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.* Blatt *Sheet*
R 50490199 0001

Ihr Zeichen *Client Reference* Unser Zeichen *Our Reference* Ausstellungsdatum *Date of Issue*
R.R. 01-YangYongM-NN20RX3F 001 12.01.2021 (day/mo/yr)

Genehmigungsinhaber *License Holder* Fertigungsstätte *Manufacturing Plant*
Zhuhai Telehof Electrics Company Limited Zhuhai Telehof Electrics Company Limited
No.6 Jinhua Road, No.6 Jinhua Road,
Xiaolin, Hongqi Town, Xiaolin, Hongqi Town,
Jinwan District, Zhuhai Jinwan District, Zhuhai
Guangdong Guangdong
P.R. China P.R. China

Prüfzeichen *Test Mark* Geprüft nach *Tested acc. to*
EN 61643-11:2012+A11



Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)* Lizenzentgelte - Einheit *License Fee - Unit*

Surge Protector (Surge Protective Device)

Type Designation: BT P BCM12.5 275 RM; BT P BCM25 255 RM; 8
BT P BCM12.5 275 RM/XP;
BT P BCM12.5 275 RM/Y+N;
X=2,3,4; Y=1,2,3
Trade mark : Telebahn
Uc : 320 V AC(L-N); 255 V AC(N-PE)
Iimp(10/350) : 12.5 kA(L-N); 37.5 kA(N-PE)
In : 30 kA(L-N); 50 kA(N-PE)
Imax : 60 kA(L-N); 100 kA(N-PE)
Up : 1.8 kV(L-N); 1.5 kA(N-PE)
Ures : 1.32 kV@Iimp
Iscrr : 25 kA
Max. backup fuse: 160 A gL/gG
Type of SPD : Type 1 + Type 2
Location : indoor
Temperature : -40°C to 80°C
Remark: MCOV of MOV is 320 V AC for the above SPDs.



8

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

Zertifizierungsstelle

Zhao Xinhua

Zhuhai Telehof Electrics Company
Limited
Richard Ruenata

Date : 12.01.2021
Our ref. : YangYongM 01
Your ref.: R.R.

No.6 Jinhua Road,
Xiaolin, Hongqi Town,
Jinwan District, Zhuhai
Guangdong
P.R. China

Ref : R TÜV-Mark Approval

Type of Equipment : Surge Protective Device
Model Designation : See Certificate
Certificate No. : R 50490199 0001
Report No. : NN20RX3F 001

Dear Richard Ruenata,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Enclosed you will find the certificate of approval.

If cancellation of the certificate is submitted by November 15 in a given year, no fee will be charged for the following year.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Please contact our office for approval of your new products.

With kind regards,

Certification Body



Zhao Xinhua

cc: Zhuhai Telehof Electrics Company

Enclosure

证书的详细资料请登录www.tuvdotcom.com 查阅, 或拨打我司客服热线 800 999 3668/400 883 1300 咨询